



Ref. Certif. No.

CN43401

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

Product  
Produit

Switch capacitor contactor

Name and address of the applicant  
Nom et adresse du demandeur

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

Name and address of the manufacturer  
Nom et adresse du fabricant

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

Name and address of the factory  
Nome et adresse de l'usine

Zhejiang Tengen Electric Co.,Ltd.  
No. 2777, West Zhongshan Road, Xiuzhou District, Jiaxing  
City, Zhejiang,Province

Note: When more than one factory, please report on page 2  
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2<sup>me</sup> page

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)  
Marque de fabrique (si elle existe)

TENGEN

Model / Type Ref.  
Ref. De type

TGCC1-32,TGCC1-43

Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire, peuvent être  
indiqués sur la 2<sup>me</sup> page)

PUBLICATION EDITION

IEC 60947-4-1:2009(3rd Edition) + AMD 1:2012

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

(2018)FQIIDQ-0551

As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: May.22,2018

Signature:

Wang Kejiao

Issued 2003-05  
China Quality Certification Centre  
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86-10-83886666  
Fax: +86-10-83886282

website  
www.cqc.com.cn

CB 0044257



TGCC1-32,TGCC1-43  
Uimp:6kV;Ui:690V;lth:32A  
(TGCC1-32),43A (TGCC1-43);  
Ue:AC220V/230V,AC380V/400V,AC660V/690V;  
Ie:23A(TGCC1-32),29A(TGCC1-43);  
Utilization category:AC-6b;  
Us:AC110V,AC220V,AC380V,AC400V,AC415V,50Hz;AC110V,AC220V,AC380V,AC400V,  
AC415V,50/60Hz;  
TGCC1-32: Qe:10kvar(220V/230V),20kvar(380V/400V),26kvar(660V/690V);  
TGCC1-43:Qe:15kvar(220V/230V),25kvar(380V/400V), 36kvar(660V/690V);  
3P;  
IP20;  
Matching auxiliary contact:lth:10A,1NO,1NC;  
Switch contactor: lth:10A,1NO,1NC;  
AC-15:380V/0.95A,DC-13:220V/0.15A

Page 1 of 1

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: May.22,2018

Signature:



Wang Kejiao