

产品认证证书

II型自愿认证

证书编号: CQC2011010302501116

发证日期: 2020年11月02日

有效期至: 2031年05月20日

委托人名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

制造商名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

生产企业名称 浙江金莱勒电气有限公司
及生产地址 浙江省乐清市乐清经济开发区纬十路 246 号

产品名称和系列、规格、型号 负荷隔离开关
GL□-□/□□□□□、GLS□-□/□□□□□ ;Uimp :12kV ;Ui :1000V ;Ith :1600A ;Ue :AC380/400V ;
Ie : 800A、1000A、1250A、1600A ;使用类别 : AC-21B ;Icw : 30kA/1s ;Icm (峰值) :
63kA ;极数 : 3P、4P ;配用的辅助触头 : Ith : 0.8A ; 1NO1NC ; 2NO2NC ; AC-15 : Ue/Ie :
220V/0.8A

产品标准和技术要求 GB/T 14048.3-2017

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人 签发

陈昕 陆楠

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0056325

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2011010302501116

Valid from: Nov.02,2020

Valid until: May.20,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND LOCATION OF THE FACTORY Zhejiang GRL Electric Co.,Ltd.
No.246 Wei 10th Road, Yueqing Economic Development Zone, Yueqing, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION Switch-disconnector
GL₂-□/□□□□□, GLS₂-□/□□□□□ ; Uimp : 12kV ; Ui : 1000V ; Ith : 1600A ; Ue : AC380/400V ; Ie : 800A, 1000A, 1250A, 1600A ; AC-21B ; Icw : 30kA/1s ; Icm (peak) : 63kA ; 3P, 4P ; Auxilliary contacts : Ith : 0.8A ; 1NO1NC ; 2NO2NC ; AC-15 : Ue/Ie : 220V/0.8A



THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.3-2017

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY
 SIGNATURE


CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86 10 83886666

C(2) 0056325

产品认证证书

II型自愿认证

附 录

证书编号: CQC2011010302501116

第 1 页 共 1 页

纸 号: 56325

型号的解释:

$\frac{\square}{(1)}$ $\frac{\square}{(2)}$ - $\frac{\square}{(3)}$ / $\frac{\square}{(4)}$ $\frac{\square}{(5)}$ $\frac{\square}{(6)}$ $\frac{\square}{(7)}$ $\frac{\square}{(8)}$

- (1) “GL”表示负荷隔离开关,“GLS”表示负荷隔离开关
- (2) 操作方式:“C”表示侧方正面操作,“Z”表示上下两个负荷开关转换操作,
“Z2”表示左右转换操作,不需要时不注
- (3) 额定电流(A): 800、1000、1250、1600
- (4) 极数: 3-3P, 4-4P
- (5) “J”表示柜外操作,柜内操作不注
- (6) “H”表示柜后操作,不需要时不注
- (7) “K”表示带可视窗口,不需要时不注
- (8) 辅助触点功能代号:“11”表示一常开一常闭,“22”表示二常开二常闭

注:此附录与证书同时使用时有效。



中国质量认证中心

