



# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE230303008316

**Product**

Moulded Case Circuit-breakers

**Applicant**

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**Type/Model**

TGM1N-63L/M/H/R, TGMK-63L/M/H/R, TGMG-63L/M/H/R, TGMH-63L/M/H/R,  
TGM1N-125L/M/H/R, TGMK-125L/M/H/R, TGMG-125L/M/H/R, TGMH-125L/M/H/R;

**Technical data**

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2022CQC0303-012869, the submitted sample(s) of the above item complies with:

**EN 60947-2:2017/A1:2020; EN 60947-2:2017**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

**Valid from: Jun.20,2023**

**Valid until: Jun.19,2026**

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE







# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE230303008316

TGM1N-63L/M/H/R, TGMK-63L/M/H/R, TGMG-63L/M/H/R, TGMH-63L/M/H/R,  
TGM1N-125L/M/H/R, TGMK-125L/M/H/R, TGMG-125L/M/H/R, TGMH-125L/M/H/R  
Uimp: 8kV;  
Ui: 800V;  
Ue: AC230V/240V/AC380V/AC400V/AC415V(Only 2P),  
AC380V/AC400V/AC415V/AC660V/690V (Except 2P);  
In: 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A  
(TGM1N-63L/M/H/R, TGMK-63L/M/H/R, TGMG-63L/M/H/R, TGMH-63L/M/H/R);  
10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A, 125A  
(TGM1N-125L/M/H/R, TGMK-125L/M/H/R, TGMG-125L/M/H/R, TGMH-125L/M/H/R);  
Over-current release: Thermo-magnetic;  
Ics: AC230/240V:25kA(Type L), 35kA(Type M);  
AC380/400/415V: 18kA(Type L), 25kA(Type M), 35kA(Type H), 50kA(Type R);  
AC660/690V: 5kA(Type L), 5kA(Type M), 8kA(Type H), 10kA(Type R);  
Icu: AC230/240V: 35kA(Type L), 50kA(Type M);  
AC380/400/415V: 25kA(Type L), 35kA(Type M), 50kA(Type H), 70kA(Type R);  
AC660/690V: 5kA(Type L), 5kA(Type M), 8kA(Type H), 10kA(Type R);  
Selectivity category: A;  
2P(Only Type L/M), 3P, 3P+N, 4P;  
Suitable for isolation(Except 3P+N);  
50/60Hz;  
IP20;  
Electronic Accessories complied with Annex N:  
Shunt release FT: AC220/230/240V, AC380/400/415V;  
Undervoltage release QT: AC220/230/240V, AC380/400/415V;  
Electric operator CD2: AC220/230/240V, AC380/400/415V;  
Auxiliary contacts (1NO1NC, 2NO2NC, 4NO4NC):  
Ith: 3A;  
AC-15: Ue/Ie: AC380/400/415V/0.3A;  
DC-13: Ue/Ie: DC110/220/250V/0.15A



CHINA QUALITY CERTIFICATION CENTRE

