

IEC**IECEE**

®

TM

Ref. Certif. No.

CN67743

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Moulded case circuit breaker

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

*Note: When more than one factory, please report on page 2*Yueqing Economic Development Branch of Zhejiang Tengen
Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City,
Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

TGM3-800L,TGM3-800M,TGM3-800H,TGM3-800R;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th Edition);IEC 60947-1:2007;IEC 60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

(2024)FQIIDQ-1190

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.21,2024

Signature:

谢肇煦

Xie ZhaoXu



TGM3-800L,TGM3-800M,TGM3-800H,TGM3-800R;
Ui:1000V;Uimp:12kV;
Ue:AC380V/AC400V/AC415V;
In: 400A,500A,600A,630A,650A,700A,800A;
Type of over-current release:Thermo-magnetic;
Trip class:20;
Type L:Ics:50kA,Icu:50kA;Type M:Ics:70kA,Icu:70kA;
Type H:Ics:75kA,Icu:100kA;Type R:Ics:100kA,Icu:100kA;
Selectivity category:A;50Hz/60Hz;
3P,4P,3P+N;Suitable for isolation(Except 3P+N);
Matching auxiliary contact: OF3M40,
Alarm contact: SD3M40:1NO1NC,2NO2NC;
Ui:690V;lth:5A;AC-15:AC380V/400V/415V/0.3A;
DC-13:DC110V/220V/250V/0.15A;
Electronic accessory complying with annex N:
Motor-operator:AC/DC 110V/220V/230V/240V,
AC380V/AC400V/AC415V;
Undervoltage release: AC220V/ AC230V/AC240V,
AC380V/AC400V/AC415.

Page 1 of 1

Additional information (if necessary)

Date:

Nov.21,2024

Signature:

谢肇煦

Xie ZhaoXu