

IEC

IECEE
CB
SCHEME

Ref. Certif. No.

CN47518

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit-breakers

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

Zhejiang Tengen Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City,
Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TGM1N-400L/M/H, TGM1N-630L/M/H, TGMD-400L/M/H,
TGMD-630L/M/H

Additional information (if necessary may also be reported on page 2)

IEC 60947-2:2006(4th Edition) + AMD 1:2009 + AMD 2:2013

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2017CQC-075290

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>



Date: Jul.22,2019

Signature:

Lu Mei

CB 0050957

TGM1N-400L/M/H, TGM1N-630L/M/H, TGMD-400L/M/H, TGMD-630L/M/H

Ui:1000V;

Uimp:12kV;

Ue:AC380/400/415V,AC660/690V;

In:

TGM1N-400L/M/H, TGMD-400L/M/H: 250A,280A,300A,315A,320A,350A,380A,400A;

TGM1N-630L/M/H, TGMD-630L/M/H: 400A,450A,500A,550A,600A,630A;

Over-current release: thermal-magnetic;

Ics: AC380/400/415V:35kA(Type L),50kA(Type M),75kA(Type H);

AC660/690V:10kA(Type L),10kA(Type M),10kA(Type H);

Icu: AC380/400/415V:50kA(Type L),70kA(Type M),100kA(Type H);

AC660/690V:10kA(Type L),15kA(Type M),20kA(Type H);

Selectivity category: A;

50/60Hz;

Poles:3P,3P+N,4P;

IP20

Suitable for insulation(except for 3P+N)

Auxiliary contact OF-M, Alarm contact SD-M (1NO1NC,2NO2NC,4NO4NC):

Ui:690V;

Ith: 6A;

Ue/Ie:

AC-15: AC380/400/415V/1A;

DC-13: DC110/220/250V/0.15A;

Accessories with electronic circuits:

Undervoltage release(QT): AC220/230/240V,AC380/400/415V;

Shunt release(FT): AC220/230/240V,AC380/400/415V;

Motor operator (CD2): AC220/230/240V,AC380/400/415V

Page 1 of 1

Additional information (if necessary)

Date: Jul.22,2019

Signature:



Lu Mei