

Test Report issued under the responsibility of:



TEST REPORT
EN 60947-4-1
Low voltage switchgear and controlgear
Part 4: Contactors and motor-starters
Section 1 - Electromechanical contactors and motor-starters

Report Number.....: CE2024CQC0305-015503
Date of issue.....: 2024.12.20
Total number of pages.....: 27 pages

Name of Testing Laboratory preparing the Report.....: ZhongJian Quality Test and Certification Research Institute Co.,Ltd.

Applicant's name.....: Zhejiang Tengen Electric Co.,Ltd.
Address.....: Sulv Industrial Area, Lushi Town, Yueqing City, Zhejiang Province, P.R.China

Test specification:
Standard.....: EN IEC 60947-4-1:2019
Test procedure.....: CCA
Non-standard test method.....: N/A

Test Report Form No.....: EN60947_4_1C
Test Report Form(s) Originator.....: DEKRA Certification B.V.
Master TRF.....: Dated 2017-06

Copyright © 2017 EN IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (EN IEC System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the EN IEC is acknowledged as copyright owner and source of the material. EN IEC takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-EN IEC members, the EN/IECEN logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with EN IEC 02.

General disclaimer:

The test results presented in this report relate only to the object tested.
This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description	Electromechanical contactor
Trade Mark	/
Manufacturer	Zhejiang Tengen Smart Electrics Co., Ltd.
Model/Type reference	TGCA-265, TGCA-330, TGCA-400 TGC1-265, TGC1-330, TGC1-400
Ratings	<p>Ui:1140V,1000V(TGCA);1000V(TGC1); Uimp:12kV;3P; Ue;AC220V/230V,AC380V/400V,AC660V/690V,AC1140V(TGCA); AC220V/230V,AC380V/400V,AC660V/690V(TGC1); TGCA-265:315A (Ith); AC-1:Ue/Ie:AC220V/230V/315A,AC380V/400V/315A,AC660V/690V/315A, AC1140V/315A; AC-3:Ue/Ie:AC220V/230V/265A,AC380V/400V/265A,AC660V/690V/170A, AC1140V/80A; AC-4:Ue/Ie:AC220V/230V/265A,AC380V/400V/265A,AC660V/690V/137A; TGCA-330:380A(Ith); AC-1:Ue/Ie:AC220V/230V/380A,AC380V/400V/380A,AC660V/690V/380A, AC1140V/380A; AC-3:Ue/Ie:AC220V/230V/330A,AC380V/400V/330A,AC660V/690V/235A, AC1140V/100A; AC-4:Ue/Ie:AC220V/230V/330A,AC380V/400V/330A,AC660V/690V/170A; TGCA-400: 450A (Ith); AC-1:Ue/Ie:AC220V/230V/450A,AC380V/400V/450A,AC660V/690V/450A, AC1140V/450A; AC-3:Ue/Ie:AC220V/230V/400A,AC380V/400V/400A,AC660V/690V/303A ,AC1140V/128A; AC-4:Ue/Ie:AC220V/230V/330A,AC380V/400V/330A,AC660V/690V/235A; TGC1-265:315A (Ith); AC-1:Ue/Ie:AC220V/230V/315A,AC380V/400V/315A,AC660V/690V/315A; AC-3:Ue/Ie:AC220V/230V/265A,AC380V/400V/265A,AC660V/690V/170A; AC-4:Ue/Ie:AC220V/230V/265A,AC380V/400V/265A,AC660V/690V/137A; TGC1-330:380A(Ith); AC-1:Ue/Ie:AC220V/230V/380A,AC380V/400V/380A,AC660V/690V/380A; AC-3:Ue/Ie:AC220V/230V/330A,AC380V/400V/330A,AC660V/690V/235A; AC-4:Ue/Ie:AC220V/230V/330A,AC380V/400V/330A,AC660V/690V/170A; TGC1-400:450A (Ith); AC-1:Ue/Ie:AC220V/230V/450A,AC380V/400V/450A,AC660V/690V/450A; AC-3:Ue/Ie:AC220V/230V/400A,AC380V/400V/400A,AC660V/690V/303A; AC-4:Ue/Ie:AC220V/230V/330A,AC380V/400V/330A,AC660V/690V/235A; Us:AC/DC110V~127V,AC/DC220V~240V,AC/DC380V~415V;</p>

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/>	CB Testing Laboratory:	ZhongJian Quality Test and Certification Research Institute Co.,Ltd.
Testing location/ address.....:		No.352 Banshan Road Hangzhou,Zhejiang,P.R .CHINA
Tested by (name, function, signature).....:		Wei Yisong <i>Wei yi song</i> Manager of technology department
Approved by (name, function, signature)::		Zeng Zheng <i>Zeng zheng</i> Deputy director
<hr/>		
<input type="checkbox"/>	Testing procedure: CTF Stage 1:	
Testing location/ address..... :		
	Tested by (name, function, signature).....:	
	Approved by (name, function, signature)::	
<hr/>		
<input type="checkbox"/>	Testing procedure: CTF Stage 2:	
Testing location/ address..... :		
	Tested by (name + signature).....:	
Witnessed by (name, function, signature):		
	Approved by (name, function, signature)::	
<hr/>		
<input type="checkbox"/>	Testing procedure: CTF Stage 3:	
<input type="checkbox"/>	Testing procedure: CTF Stage 4:	
Testing location/ address..... :		
	Tested by (name, function, signature).....:	
	Witnessed by (name, function, signature):	
	Approved by (name, function, signature)::	
	Supervised by (name, function, signature)	

